

Republic of the Philippines
 PROVINCE OF PANGASINAN
 Provincial Water Bacteriological Laboratory

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
20-3018	Consumers' Tap	Sta Maria Centro	< 1	<1.1	<1.1	PASSED
20-3019	Consumers' Tap	Pogo ACWD Office	1	<1.1	<1.1	PASSED
20-3020	Consumers' Tap	Victoria End Point	1	<1.1	<1.1	PASSED
20-3021	Consumers' Tap	Polo Brgy. Hall	2	<1.1	<1.1	PASSED
20-3022	Consumers' Tap	Cabatuan near School	1	<1.1	<1.1	PASSED
20-3023	Consumers' Tap	Bisocol Elementary School	< 1	<1.1	<1.1	PASSED
20-3024	Consumers' Tap	Inerangan Siobal	< 1	<1.1	<1.1	PASSED
20-3025	Consumers' Tap	Tagudin near School	5	<1.1	<1.1	PASSED
20-3026	Consumers' Tap	Landoc near School	< 1	<1.1	<1.1	PASSED
20-3027	Consumers' Tap	Baleyadaan Elementary School	2	<1.1	<1.1	PASSED
20-3028	Consumers' Tap	Lucap Maxine	2	<1.1	<1.1	PASSED
20-3029	Consumers' Tap	Palamis near School	< 1	<1.1	<1.1	PASSED
20-3030	Consumers' Tap	Pocal-pocal near School	< 1	<1.1	<1.1	PASSED
20-3031	Consumers' Tap	Tangcarang near School	< 1	<1.1	<1.1	PASSED
20-3032	Consumers' Tap	Poblacion near School	1	<1.1	<1.1	PASSED
20-3033	Consumers' Tap	Amangbangan near School	< 1	<1.1	<1.1	PASSED
20-3034	Consumers' Tap	Cayucay near School	< 1	<1.1	<1.1	PASSED
20-3035	Consumers' Tap	Tawin-tawin near School	3	<1.1	<1.1	PASSED
20-3036	Consumers' Tap	Telbang near School	< 1	<1.1	<1.1	PASSED
20-3037	Consumers' Tap	San Vicente near School	7	<1.1	<1.1	PASSED
20-3038	Pump House	Cabatuan I, Alaminos City	2	<1.1	<1.1	PASSED
20-3039	Pump House	Cabatuan III, Alaminos City	< 1	<1.1	<1.1	PASSED
20-3040	Pump House	Sabangan Spring 40HP	< 1	<1.1	<1.1	PASSED
20-3041	Pump House	Sabangan Spring 25HP, Alaminos City	< 1	<1.1	<1.1	PASSED

PROVINCE OF PANGASINAN
Provincial Water Bacteriological Laboratory

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
20-3042	Pump House	Linmansangan, Alaminos City	1	<1.1	<1.1	PASSED
20-3043	Pump House	San Vicente, Alaminos City	< 1	< 1.1	< 1.1	PASSED
20-3044	Pump House	Balangobong I, Alaminos City	< 1	< 1.1	< 1.1	PASSED
20-3045	Pump House	Balangobong II, Alaminos City	2	<1.1	<1.1	PASSED
20-3046	Pump House	Quibuar I Alos	1	< 1.1	< 1.1	PASSED
20-3047	Pump House	Quibuar II Alos	< 1	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNSDW)

Total Coliforms = <1.1 MPN/100 ml

Thermotolerant coliform/E. coli = <1.1MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: **Allen Valencia (ACWD)**

Examination Date: **October 13, 2020**


WILLY P. DE GUZMAN, RMT

Analyst