

Republic of the Philippines  
PROVINCE OF PANGASINAN  
Provincial Water Bacteriological Laboratory

**BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES**

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
19-2403	Consumers' Tap	Sta Maria Centro	<1	<1.1	<1.1	PASSED
19-2404	Consumers' Tap	Pogo ACWD Office	<1	<1.1	<1.1	PASSED
19-2405	Consumers' Tap	Victoria End Point	<1	<1.1	<1.1	PASSED
19-2406	Consumers' Tap	Polo Brgy. Hall	<1	<1.1	<1.1	PASSED
19-2407	Consumers' Tap	Cabatuan near School	<1	<1.1	<1.1	PASSED
19-2408	Consumers' Tap	Bisocol Elementary School	<1	<1.1	<1.1	PASSED
19-2409	Consumers' Tap	Inerangan Siobal	<1	<1.1	<1.1	PASSED
19-2410	Consumers' Tap	Tagudin near School	<1	<1.1	<1.1	PASSED
19-2411	Consumers' Tap	Landoc near School	<1	<1.1	<1.1	PASSED
19-2412	Consumers' Tap	Baleyadaan Elementary School	<1	<1.1	<1.1	PASSED
19-2413	Consumers' Tap	Lucap Maxine	<1	<1.1	<1.1	PASSED
19-2414	Pump House	Cabatuan I, Alaminos City	<1	<1.1	<1.1	PASSED
19-2415	Pump House	Cabatuan III, Alaminos Ciity	<1	<1.1	<1.1	PASSED
19-2416	Pump House	Sabangan Spring	<1	<1.1	<1.1	PASSED
19-2417	Pump House	Sabangan Well	<1	<1.1	<1.1	PASSED
19-2418	Pump House	Linmansangan, Alaminos City	<1	<1.1	<1.1	PASSED
19-2419	Pump House	San Vicente, Alaminos City	<1	<1.1	<1.1	PASSED
19-2420	Pump House	Balangobong I, Alaminos City	<1	<1.1	<1.1	PASSED
19-2421	Pump House	Balangobong II, Alaminos City	<1	<1.1	<1.1	PASSED
19-2422	Pump House	Quibuar I Alos	<1	<1.1	<1.1	PASSED
19-2423	Pump House	Quibuar II Alos	<1	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNSDW)


Total Coliforms = <1.1 MPN/100 ml

Thermotolerant coliform/E. coli = <1.1MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: **Allen Valencia (ACWD)**

Examination Date: **July 29, 2019**

  
**WILLY P. DE GUZMAN, RMT**  
Analyst