

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES

| Lab. No. | Name of Establishment | Address | Results of Analysis | | | REMARKS |
|----------|-----------------------|---------------------------------------|---------------------|-----------------|-----------------------------------|---------|
| | | | HPC | Total Coliforms | Thermotolerant coliforms/ E. coli | |
| 18-2789 | Consumers' Tap | Sta Maria near School | <1 | <1.1 | <1.1 | PASSED |
| 18-2790 | Consumers' Tap | Suki Market, Alaminos City | <1 | <1.1 | <1.1 | PASSED |
| 18-2791 | Consumers' Tap | Mary the Queen Educational Foundation | <1 | <1.1 | <1.1 | PASSED |
| 18-2792 | Consumers' Tap | Alaminos City Central School | <1 | <1.1 | <1.1 | PASSED |
| 18-2793 | Consumers' Tap | PASS College, Alaminos City | <1 | <1.1 | <1.1 | PASSED |
| 18-2794 | Consumers' Tap | Food Court near Legislative | <1 | <1.1 | <1.1 | PASSED |
| 18-2795 | Consumers' Tap | Jollibee, Alaminos City | 1 | <1.1 | <1.1 | PASSED |
| 18-2796 | Consumers' Tap | Golden West College, Alaminos City | <1 | <1.1 | <1.1 | PASSED |
| 18-2797 | Consumers' Tap | Nepo Mall, Alaminos City | <1 | <1.1 | <1.1 | PASSED |
| 18-2798 | Consumers' Tap | Colegio de San Jose, Alaminos City | <1 | <1.1 | <1.1 | PASSED |
| 18-2799 | Consumers' Tap | Exchange fast Food, Alaminos City | <1 | <1.1 | <1.1 | PASSED |
| 18-2800 | Pump House | Cabatuan I, Alaminos City | <1 | <1.1 | <1.1 | PASSED |
| 18-2801 | Pump House | Sabangan Spring 40HP, alaminos City | <1 | <1.1 | <1.1 | PASSED |
| 18-2802 | Pump House | Sabangan Well, Alaminos City | <1 | <1.1 | <1.1 | PASSED |
| 18-2803 | Pump House | Cabatuan III, Alaminos City | <1 | <1.1 | <1.1 | PASSED |
| 18-2804 | Pump House | Linmansangan, Alaminos City | <1 | <1.1 | <1.1 | PASSED |
| 18-2805 | Pump House | San Vicente, Alaminos City | <1 | <1.1 | <1.1 | PASSED |
| 18-2806 | Pump House | balangobong I, Alaminos City | <1 | <1.1 | <1.1 | PASSED |
| 18-2807 | Pump House | Quibuar I alos, Alaminos City | 1 | <1.1 | <1.1 | PASSED |
| 18-2808 | Pump House | Quibuar II alos, Alaminos City | <1 | <1.1 | <1.1 | PASSED |
| 18-2809 | Pump House | Balangobong II, Alaminos City | <1 | <1.1 | <1.1 | PASSED |

Philippine National Standards for Drinking Water (PNSDW)

Total Coliforms = <1.1 MPN/100 ml

Thermotolerant coliform/E. coli = <1.1 MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: **Michael Rasing (ACWD)**

Examination Date: **August 23, 2018**



WILLY P. DE GUZMAN, RMT

Analyst