

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Fecal Coliforms	
18-073	Household Faucet	Malimpek, Bolo II	<1	<1.1	<1.1	PASSED
18-074	Household Faucet	Baleyadaan Bukig	<1	<1.1	<1.1	PASSED
18-075	Household Faucet	Balayang Boundary Luna	<1	<1.1	<1.1	PASSED
18-076	Household Faucet	Maawi near School	<1	<1.1	<1.1	PASSED
18-077	Household Faucet	Magsaysay Kampilan, Dead End	<1	<1.1	<1.1	PASSED
18-078	Household faucet	Cabatuan after bridge	<1	<1.1	<1.1	PASSED
18-079	Household Faucet	Dulacac near School	<1	<1.1	<1.1	PASSED
18-080	Household Faucet	Landoc near School	<1	<1.1	<1.1	PASSED
18-081	Household Faucet	Mangrove, Buead	<1	<1.1	<1.1	PASSED
18-082	Household Faucet	Inerangan, Cardinal St.	<1	<1.1	<1.1	PASSED
18-083	Household Faucet	Amangbangan near School	<1	<1.1	<1.1	PASSED
18-084	Pump House	Linmansangan, Alaminos City	<1	<1.1	<1.1	PASSED
18-085	Pump House	Cabatuan I, Alaminos City	<1	<1.1	<1.1	PASSED
18-086	Pump House	Cabatuan III, Alaminos City	<1	<1.1	<1.1	PASSED
18-087	Pump House	Quibuar, Alaminos City	<1	<1.1	<1.1	PASSED
18-088	Pump House	Quibuar II, Alaminos City	<1	<1.1	<1.1	PASSED
18-089	Pump House	Sabangan Spring, alaminos City	<1	<1.1	<1.1	PASSED
18-090	Pump House	Sabangan Well, alaminos City	<1	<1.1	<1.1	PASSED
18-091	Pump House	Balangobong I, Alaminos City	<1	<1.1	<1.1	PASSED
18-092	Pump House	Balangobong II, Alaminos City	<1	<1.1	<1.1	PASSED
18-093	Pump House	San Vicente, Alaminos City	<1	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNSDW)

Total Coliforms = <1.1 MPN/100 ml

Fecal Coliforms = <1.1 MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: Jojo Cabatic (ACWD)

Examination Date: January 19, 2018

WILLY P. DE GUZMAN, RMT

Analyst