

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Fecal Coliforms	
18-1667	Consumer's Tap	San Jose near School	< 1	<1.1	<1.1	PASSED
18-1668	Consumer's Tap	Riverside Cabatuan Dead end	< 1	<1.1	<1.1	PASSED
18-1669	Consumer's Tap	Inerangan going to San Miguel	< 1	<1.1	<1.1	PASSED
18-1670	Consumer's Tap	Victoria going to Maxine Paradise	< 1	<1.1	<1.1	PASSED
18-1671	Consumer's Tap	Sitio Babasit, Mona	< 1	<1.1	<1.1	PASSED
18-1672	Consumer's Tap	Amangbangan Bliss	< 1	<1.1	<1.1	PASSED
18-1673	Consumer's Tap	Dulacac near Dumpsite	< 1	<1.1	<1.1	PASSED
18-1674	Consumer's Tap	Baleyadaan Bukig	< 1	<1.1	<1.1	PASSED
18-1675	Consumer's Tap	Telbang near Ricemill	< 1	<1.1	<1.1	PASSED
18-1676	Consumer's Tap	Balayang Pocrado	< 1	<1.1	<1.1	PASSED
18-1677	Consumer's Tap	Luna, mabini	< 1	<1.1	<1.1	PASSED
18-1678	Pump House	Sabangan Spring, alaminos City	< 1	<1.1	<1.1	PASSED
18-1679	Pump House	Sabangan Well, alaminos City	< 1	<1.1	<1.1	PASSED
18-1680	Pump House	Cabatuan III, Alaminos City	< 1	<1.1	<1.1	PASSED
18-1681	Pump House	Linmansangan, Alaminos City	< 1	<1.1	<1.1	PASSED
18-1682	Pump House	San Vicente, Alaminos City	< 1	<1.1	<1.1	PASSED
18-1683	Pump House	Balangobong I, Alaminos City	< 1	<1.1	<1.1	PASSED
18-1684	Pump House	Quibuar 1 alos, Alaminos City	< 1	<1.1	<1.1	PASSED
18-1685	Pump House	Quibuar II alos, Alaminos City	< 1	<1.1	<1.1	PASSED
18-1686	Pump House	Balangobong II, Alaminos City	< 1	<1.1	<1.1	PASSED
18-1687	Pump House	Cabatuan I, Ajaminos City	< 1	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNSDW)


Total Coliforms = <1.1 MPN/100 ml

E. coli = <1.1 MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: **Allen Valencia (ACWD)**

Examination Date: **May 24, 2018**


WILLY P. DE GUZMAN, RMT

Analyst