

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES


Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
18-3555	Consumers' Tap (End Point)	Dulacac, Alaminos City	< 1	<1.1	<1.1	PASSED
18-3556	Consumers' Tap (End Point)	Sta Maria, Alaminos City	< 1	<1.1	<1.1	PASSED
18-3557	Consumers' Tap (End Point)	Siobal Inerangan near Arco	< 1	<1.1	<1.1	PASSED
18-3558	Consumers' Tap (End Point)	Luna, Mabini	< 1	<1.1	<1.1	PASSED
18-3559	Consumers' Tap (End Point)	San Roque, Alaminos City	< 1	<1.1	<1.1	PASSED
18-3560	Consumers' Tap (End Point)	San Miguel, Bani	< 1	<1.1	<1.1	PASSED
18-3561	Consumers' Tap (End Point)	Calzada, Bani	< 1	<1.1	<1.1	PASSED
18-3562	Consumers' Tap (End Point)	Amangbangan, Alaminos City	< 1	<1.1	<1.1	PASSED
18-3563	Consumers' Tap (End Point)	Tawin-Tawin, Alaminos City	< 1	<1.1	<1.1	PASSED
18-3564	Consumers' Tap (End Point)	Sitio Soliba, Tawin-Tawin, Alaminos	< 1	<1.1	<1.1	PASSED
18-3565	Consumers' Tap (End Point)	San Jose, Alaminos City	< 1	<1.1	<1.1	PASSED
18-3566	Pump House	Cabatuan I, Alaminos City	< 1	<1.1	<1.1	PASSED
18-3567	Pump House	Sabangan Spring 40HP, alaminos City	< 1	<1.1	<1.1	PASSED
18-3568	Pump House	Sabangan Well, Alaminos City	< 1	<1.1	<1.1	PASSED
18-3569	Pump House	Cabatuan III, Alaminos City	< 1	<1.1	<1.1	PASSED
18-3570	Pump House	Limansangan, Alaminos City	< 1	<1.1	<1.1	PASSED
18-3571	Pump House	San Vicente, Alaminos City	< 1	<1.1	<1.1	PASSED
18-3572	Pump House	Balangobong I, Alaminos City	< 1	<1.1	<1.1	PASSED
18-3573	Pump House	Quibuar I alos, Alaminos City	1	<1.1	<1.1	PASSED
18-3574	Pump House	Quibuar II alos, Alaminos City	< 1	<1.1	<1.1	PASSED
18-3575	Pump House	Balangobong II, Alaminos City	< 1	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNSDW)

Total Coliforms = <1.1 MPN/100 ml

Thermotolerant coliform/E. coli = <1.1 MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml


 WILLY P. DE GUZMAN, RMT
 Analyst

Submitted by: Michael Rasing (ACWD)

Examination Date: October 18, 2018