

**BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES**


Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
18-3282	Consumers' Tap	Baleyadaan Elementary School	<1	<1.1	<1.1	PASSED
18-3283	Consumers' Tap	Magsaysay Elementary School	<1	<1.1	<1.1	PASSED
18-3284	Consumers' Tap	Balagobong Elementary School	<1	<1.1	<1.1	PASSED
18-3285	Consumers' Tap	Cabatuan Elementary School	<1	<1.1	<1.1	PASSED
18-3286	Consumers' Tap	Popantay Elementary School	<1	<1.1	<1.1	PASSED
18-3287	Consumers' Tap	Palamis Elementary School	<1	<1.1	<1.1	PASSED
18-3288	Consumers' Tap	Lucap Elementary School	<1	<1.1	<1.1	PASSED
18-3289	Consumers' Tap	Pogo Elementary School	<1	<1.1	<1.1	PASSED
18-3290	Consumers' Tap	Bued Elementary School	<1	<1.1	<1.1	PASSED
18-3291	Consumers' Tap	Alaminos City National High School	<1	<1.1	<1.1	PASSED
18-3292	Consumers' Tap	Maliga Elementary School	<1	<1.1	<1.1	PASSED
18-3293	Pump House	Cabatuan I, Alaminos City	<1	<1.1	<1.1	PASSED
18-3294	Pump House	Sabangan Spring 40HP, alaminos City	1	<1.1	<1.1	PASSED
18-3295	Pump House	Sabangan Well, Alaminos City	<1	<1.1	<1.1	PASSED
18-3296	Pump House	Cabatuan III, Alaminos City	<1	<1.1	<1.1	PASSED
18-3297	Pump House	Linmansangan, Alaminos City	<1	<1.1	<1.1	PASSED
18-3298	Pump House	San Vicente, Alaminos City	<1	<1.1	<1.1	PASSED
18-3299	Pump House	Balangobong I, Alaminos City	<1	<1.1	<1.1	PASSED
18-3300	Pump House	Quibuar I alos, Alaminos City	<1	<1.1	<1.1	PASSED
18-3301	Pump House	Quibuar II alos, Alaminos City	<1	<1.1	<1.1	PASSED
18-3302	Pump House	Balangobong II, Alaminos City	<1	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNSDW)

Total Coliforms = <1.1 MPN/100 ml  
 Thermotolerant coliform/E. coli = <1.1 MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: **Allen Valencia (ACWD)**  
 Examination Date: **September 26, 2018**

  
**WILLY P. DE GUZMAN, RMT**  
 Analyst