

Republic of the Philippines
 PROVINCE OF PANGASINAN
 Provincial Water Bacteriological Laboratory

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES


Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
19-695	Consumers' Tap	Bisocol Elementary School	<1	<1.1	<1.1	PASSED
19-696	Consumers' Tap	Mabini Poblacion	<1	<1.1	<1.1	PASSED
19-697	Consumers' Tap	Cayucay Elementary School	<1	<1.1	<1.1	PASSED
19-698	Consumers' Tap	Landoc Elementary School	<1	<1.1	<1.1	PASSED
19-699	Consumers' Tap	Macatiw near Seminary	<1	<1.1	<1.1	PASSED
19-700	Consumers' Tap	ACWD Main Office	<1	<1.1	<1.1	PASSED
19-701	Consumers' Tap	Dulacac near Dump Site	<1	<1.1	<1.1	PASSED
19-702	Consumers' Tap	Telbang Sigking End Point	<1	<1.1	<1.1	PASSED
19-703	Consumers' Tap	Amangbangan Bliss	<1	<1.1	<1.1	PASSED
19-704	Consumers' Tap	Maliga Elementary School	<1	<1.1	<1.1	PASSED
19-705	Pump House	Cabatuan I, Alaminos City	<1	<1.1	<1.1	PASSED
19-706	Pump House	Sabangan Spring 40HP, alaminos City	1	<1.1	<1.1	PASSED
19-707	Pump House	Sabangan Well, Alaminos City	<1	<1.1	<1.1	PASSED
19-708	Pump House	Cabatuan III, Alaminos City	<1	<1.1	<1.1	PASSED
19-709	Pump House	Limansangan, Alaminos City	<1	<1.1	<1.1	PASSED
19-710	Pump House	San Vicente, Alaminos City	<1	<1.1	<1.1	PASSED
19-711	Pump House	Balangobong I, Alaminos City	<1	<1.1	<1.1	PASSED
19-712	Pump House	Quibuar I alos, Alaminos City	<1	<1.1	<1.1	PASSED
19-713	Pump House	Balangobong II, Alaminos City	<1	<1.1	<1.1	PASSED
19-714	Consumers' Tap	San Antonio Brgy Hall, Alaminos City	<1	<1.1	<1.1	PASSED
19-715	Consumers' Tap	Pocal-pocal Elementary School	<1	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNSDW)

Total Coliforms = <1.1 MPN/100 ml

Thermotolerant coliform/E. coli = <1.1 MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml



Submitted by: **Michael Rasing (ACWD)**

Examination Date: February 22, 2019

Analyst