

Republic of the Philippines  
 PROVINCE OF PANGASINAN  
 Provincial Water Bacteriological Laboratory

**BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES**

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
19-3169	Consumers' Tap	Sta Maria Centro	<1	<1.1	<1.1	PASSED
19-3170	Consumers' Tap	Pogo ACWD Office	1	<1.1	<1.1	PASSED
19-3171	Consumers' Tap	Victoria End Point	<1	<1.1	<1.1	PASSED
19-3172	Consumers' Tap	Polo Brgy. Hall	<1	<1.1	<1.1	PASSED
19-3173	Consumers' Tap	Cabatuan near School	1	<1.1	<1.1	PASSED
19-3174	Consumers' Tap	Bisocol Elementary School	<1	<1.1	<1.1	PASSED
19-3175	Consumers' Tap	Inerangan Siobal	1	<1.1	<1.1	PASSED
19-3176	Consumers' Tap	Tagudin near School	<1	<1.1	<1.1	PASSED
19-3177	Consumers' Tap	Landoc near School	<1	<1.1	<1.1	PASSED
19-3178	Consumers' Tap	Baleyadaan Elementary School	<1	<1.1	<1.1	PASSED
19-3179	Consumers' Tap	Lucap Maxine	1	<1.1	<1.1	PASSED
19-3180	Pump House	Cabatuan I, Alaminos City	<1	<1.1	<1.1	PASSED
19-3181	Pump House	Cabatuan III, Alaminos City	<1	<1.1	<1.1	PASSED
19-3182	Pump House	Sabangan Spring	<1	<1.1	<1.1	PASSED
19-3183	Pump House	Sabangan Well	1	<1.1	<1.1	PASSED
19-3184	Pump House	Linmansangan, Alaminos City	<1	<1.1	<1.1	PASSED
19-3185	Pump House	San Vicente, Alaminos City	<1	<1.1	<1.1	PASSED
19-3186	Pump House	Balangobong I, Alaminos City	<1	<1.1	<1.1	PASSED
19-3187	Pump House	Balangobong II, Alaminos City	<1	<1.1	<1.1	PASSED
19-3188	Pump House	Quibuar I Alos	<1	<1.1	<1.1	PASSED
19-3189	Pump House	Quibuar II Alos	<1	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNSDW)

Total Coliforms = <1.1 MPN/100 ml

Thermotolerant coliform/E. coli = <1.1 MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: **Allen Valencia (ACWD)**

Examination Date: August 22, 2019

W.P.G.  
**WILLY P. DE GUZMAN, RMT**

Analyst