

Republic of the Philippines
 PROVINCE OF PANGASINAN
 Provincial Water Bacteriological Laboratory



BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
20-641	Consumers' Tap	Sta Maria Centro	<1	<1.1	<1.1	PASSED
20-642	Consumers' Tap	Pogo ACWD Office	2	<1.1	<1.1	PASSED
20-643	Consumers' Tap	Victoria End Point	<1	<1.1	<1.1	PASSED
20-644	Consumers' Tap	Polo Brgy. Hall	<1	<1.1	<1.1	PASSED
20-645	Consumers' Tap	Cabatuan near School	<1	<1.1	<1.1	PASSED
20-646	Consumers' Tap	Bisocol Elementary School	<1	<1.1	<1.1	PASSED
20-647	Consumers' Tap	Inerangan Siobal	<1	<1.1	<1.1	PASSED
20-648	Consumers' Tap	Tagudin near School	1	<1.1	<1.1	PASSED
20-649	Consumers' Tap	Landoc near School	<1	<1.1	<1.1	PASSED
20-650	Consumers' Tap	Baleyadaan Elementary School	1	<1.1	<1.1	PASSED
20-651	Consumers' Tap	Lucap Maxine	<1	<1.1	<1.1	PASSED
20-652	Consumers' Tap	Palamis near School	1	<1.1	<1.1	PASSED
20-653	Consumers' Tap	Pocal-pocal near School	200	<1.1	<1.1	PASSED
20-654	Consumers' Tap	Tangcarang near School	<1	<1.1	<1.1	PASSED
20-655	Consumers' Tap	Poblacion near School	<1	<1.1	<1.1	PASSED
20-656	Consumers' Tap	Amangbangan near School	<1	<1.1	<1.1	PASSED
20-657	Consumers' Tap	Cayukey near School	627	<1.1	<1.1	FAILED
20-658	Consumers' Tap	Tawin-tawin near School	2	<1.1	<1.1	PASSED
20-659	Consumers' Tap	Telbang near School	<1	<1.1	<1.1	PASSED
20-660	Consumers' Tap	San Vicente near School	<1	<1.1	<1.1	PASSED
20-661	Pump House	Cabatuan I, Alaminos City	<1	<1.1	<1.1	PASSED
20-662	Pump House	Cabatuan III, Alaminos City	1,710	<1.1	<1.1	FAILED
20-663	Pump House	Sabangan Spring 40HP	1	<1.1	<1.1	PASSED
20-664	Pump House	Sabangan Spring 25HP, Alaminos City	40	<1.1	<1.1	PASSED

CERTIFIED BY EN ISO 9001:2015

Republic of the Philippines
PROVINCE OF PANGASINAN
Provincial Water Bacteriological Laboratory

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES

050-058-08-050
 050-058-08-050
 050-058-08-050

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
20-665	Pump House	Linmansangan, Alaminos City	< 1	<1.1	<1.1	PASSED
20-666	Pump House	San Vicente, Alaminos City	< 1	< 1.1	< 1.1	PASSED
20-667	Pump House	Balangobong I, Alaminos City	< 1	< 1.1	< 1.1	PASSED
20-668	Pump House	Balangobong II, Alaminos City	< 1	<1.1	<1.1	PASSED
20-669	Pump House	Quibuar I Alos	5	< 1.1	< 1.1	PASSED
20-670	Pump House	Quibuar II Alos	1	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNSDW)

Total Coliforms = <1.1 MPN/100 ml
 Thermotolerant coliform/E. coli = <1.1MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: Allen Valencia (ACWD)
Examination Date: February 27, 2020


WILLY P. DE GUZMAN, RMT
Analyst

