

Republic of the Philippines
 PROVINCE OF PANGASINAN
 Provincial Water Bacteriological Laboratory

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
20-950	Consumers' Tap	Sta Maria Centro	<1	<1.1	<1.1	PASSED
20-951	Consumers' Tap	Pogo ACWD Office	<1	<1.1	<1.1	PASSED
20-952	Consumers' Tap	Victoria End Point	<1	<1.1	<1.1	PASSED
20-953	Consumers' Tap	Polo Brgy. Hall	<1	<1.1	<1.1	PASSED
20-954	Consumers' Tap	Cabatuan near School	<1	<1.1	<1.1	PASSED
20-955	Consumers' Tap	Bisocol Elementary School	<1	<1.1	<1.1	PASSED
20-956	Consumers' Tap	Inerangan Siobal	<1	<1.1	<1.1	PASSED
20-957	Consumers' Tap	Tagudin near School	<1	<1.1	<1.1	PASSED
20-958	Consumers' Tap	Landoc near School	<1	<1.1	<1.1	PASSED
20-959	Consumers' Tap	Baleyadaan Elementary School	1	<1.1	<1.1	PASSED
20-960	Consumers' Tap	Lucap Maxine	<1	<1.1	<1.1	PASSED
20-961	Consumers' Tap	Palamis near School	<1	<1.1	<1.1	PASSED
20-962	Consumers' Tap	Pocal-pocal near School	<1	<1.1	<1.1	PASSED
20-963	Consumers' Tap	Tangcarang near School	<1	<1.1	<1.1	PASSED
20-964	Consumers' Tap	Poblacion near School	<1	<1.1	<1.1	PASSED
20-965	Consumers' Tap	Amangbangan near School	<1	<1.1	<1.1	PASSED
20-966	Consumers' Tap	Cayucay near School	<1	<1.1	<1.1	PASSED
20-967	Consumers' Tap	Tawin-tawin near School	<1	<1.1	<1.1	PASSED
20-968	Consumers' Tap	Telbang near School	<1	<1.1	<1.1	PASSED
20-969	Consumers' Tap	San Vicente near School	<1	<1.1	<1.1	PASSED
20-970	Pump House	Cabatuan I, Alaminos City	<1	<1.1	<1.1	PASSED
20-971	Pump House	Cabatuan III, Alaminos City	<1	<1.1	<1.1	PASSED
20-972	Pump House	Sabangan Spring 40HP	<1	<1.1	<1.1	PASSED
20-973	Pump House	Sabangan Spring 25HP, Alaminos City	<1	<1.1	<1.1	PASSED

0510-088-44-010-010
 DIRECTOR: DR. J. S. S. S.
 CHIEF: MR. S. S. S.

Republic of the Philippines
 PROVINCE OF PANGASINAN
 Provincial Water Bacteriological Laboratory

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
20-974	Pump House	Linmansangan, Alaminos City	< 1	<1.1	<1.1	PASSED
20-975	Pump House	San Vicente, Alaminos City	< 1	< 1.1	< 1.1	PASSED
20-976	Pump House	Balangobong I, Alaminos City	< 1	< 1.1	< 1.1	PASSED
20-977	Pump House	Balangobong II, Alaminos City	< 1	<1.1	<1.1	PASSED
20-978	Pump House	Quibuar I Alos	< 1	< 1.1	< 1.1	PASSED
20-979	Pump House	Quibuar II Alos	< 1	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNSDW)


Total Coliforms = <1.1 MPN/100 ml

Thermotolerant coliform/E. coli = <1.1MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: **Allen Valencia (ACWD)**

Examination Date: **March 30, 2020**


WILLY P. DE GUZMAN, RMT
 Analyst