

**BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES**

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
19-3581	Consumers' Tap	Sta Maria Centro	<1	<1.1	<1.1	PASSED
19-3582	Consumers' Tap	Pogo ACWD Office	1	<1.1	<1.1	PASSED
19-3583	Consumers' Tap	Victoria End Point	<1	<1.1	<1.1	PASSED
19-3584	Consumers' Tap	Polo Brgy. Hall	<1	<1.1	<1.1	PASSED
19-3585	Consumers' Tap	Cabatuan near School	<1	<1.1	<1.1	PASSED
19-3586	Consumers' Tap	Bisocol Elementary School	<1	<1.1	<1.1	PASSED
19-3587	Consumers' Tap	Inerangan Siobal	<1	<1.1	<1.1	PASSED
19-3588	Consumers' Tap	Tagudin near School	<1	<1.1	<1.1	PASSED
19-3589	Consumers' Tap	Landoc near School	<1	<1.1	<1.1	PASSED
19-3590	Consumers' Tap	Balayadaan Elementary School	<1	<1.1	<1.1	PASSED
19-3591	Consumers' Tap	Lucap Maxine	<1	<1.1	<1.1	PASSED
19-3592	Pump House	Cabatuan I, Alaminos City	<1	<1.1	<1.1	PASSED
19-3593	Pump House	Cabatuan III, Alaminos City	<1	<1.1	<1.1	PASSED
19-3594	Pump House	Sabangan Spring	<1	<1.1	<1.1	PASSED
19-3595	Pump House	Sabangan Well	<1	<1.1	<1.1	PASSED
19-3596	Pump House	Linmansangan, Alaminos City	<1	<1.1	<1.1	PASSED
19-3597	Pump House	San Vicente, Alaminos City	<1	<1.1	<1.1	PASSED
19-3598	Pump House	Balangobong I, Alaminos City	<1	<1.1	<1.1	PASSED
19-3599	Pump House	Balangobong II, Alaminos City	<1	<1.1	<1.1	PASSED
19-3600	Pump House	Quibuar I Alos	<1	<1.1	<1.1	PASSED
19-3601	Pump House	Quibuar II Alos	1	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNS:DW)

Total Coliforms = <1.1 MPN/100 ml

Thermotolerant coliform/E. coli = <1.1 MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: **Allen Valencia (ACWD)**

Examination Date: **September 20, 2019**

**WILLY P. DE GUZMAN, RMT**

Analyst