

Republic of the Philippines
 PROVINCE OF PANGASINAN
 Provincial Water Bacteriological Laboratory

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
20-983	Consumers' Tap	Sta Maria Centro	3	<1.1	<1.1	PASSED
20-984	Consumers' Tap	Pogo ACWD Office	15	<1.1	<1.1	PASSED
20-985	Consumers' Tap	Victoria End Point	< 1	<1.1	<1.1	PASSED
20-986	Consumers' Tap	Polo Brgy. Hall	2	<1.1	<1.1	PASSED
20-987	Consumers' Tap	Cabatuan near School	7	<1.1	<1.1	PASSED
20-988	Consumers' Tap	Bisocol Elementary School	4	<1.1	<1.1	PASSED
20-989	Consumers' Tap	Inerangan Siobal	1	<1.1	<1.1	PASSED
20-990	Consumers' Tap	Tagudin near School	1	<1.1	<1.1	PASSED
20-991	Consumers' Tap	Landoc near School	< 1	<1.1	<1.1	PASSED
20-992	Consumers' Tap	Baleyadaan Elementary School	< 1	<1.1	<1.1	PASSED
20-993	Consumers' Tap	Lucap Maxine	< 1	<1.1	<1.1	PASSED
20-994	Consumers' Tap	Palamis near School	4	<1.1	<1.1	PASSED
20-995	Consumers' Tap	Pocal-pocal near School	2	<1.1	<1.1	PASSED
20-996	Consumers' Tap	Tangcarang near School	< 1	<1.1	<1.1	PASSED
20-997	Consumers' Tap	Poblacion near School	2	<1.1	<1.1	PASSED
20-998	Consumers' Tap	Amangbangan near School	3	<1.1	<1.1	PASSED
20-999	Consumers' Tap	Cayucay near School	< 1	<1.1	<1.1	PASSED
20-1000	Consumers' Tap	Tawin-tawin near School	8	<1.1	<1.1	PASSED
20-1001	Consumers' Tap	Telbang near School	< 1	<1.1	<1.1	PASSED
20-1002	Consumers' Tap	San Vicente near School	7	<1.1	<1.1	PASSED
20-1003	Pump House	Cabatuan I, Alaminos City	1	<1.1	<1.1	PASSED
20-1004	Pump House	Cabatuan III, Alaminos City	3	<1.1	<1.1	PASSED
20-1005	Pump House	Sabangan Spring 40HP	2	<1.1	<1.1	PASSED
20-1006	Pump House	Sabangan Spring 25HP, Alaminos City	1	<1.1	<1.1	PASSED

Republic of the Philippines
 PROVINCE OF PANGASINAN
 Provincial Water Bacteriological Laboratory

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES


Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
20-1007	Pump House	Linmansangan, Alaminos City	< 1	<1.1	<1.1	PASSED
20-1008	Pump House	San Vicente, Alaminos City	2	< 1.1	< 1.1	PASSED
20-1009	Pump House	Balangobong I, Alaminos City	2	< 1.1	< 1.1	PASSED
20-1010	Pump House	Balangobong II, Alaminos City	1	<1.1	<1.1	PASSED
20-1011	Pump House	Quibuar I Alos	11	< 1.1	< 1.1	PASSED
20-1012	Pump House	Quibuar II Alos	15	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNSDW)

Total Coliforms = <1.1 MPN/100 ml
 Thermotolerant coliform/E. coli = <1.1MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: **Allen Valencia (ACWD)**
 Examination Date: **April 20, 2020**


WILLY P. DE GUZMAN, RMT
 Analyst