

Republic of the Philippines  
**PROVINCE OF PANGASINAN**  
 Provincial Water Bacteriological Laboratory

**BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES**

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
19-3984	Consumers' Tap	Sta Maria Centro	<1	<1.1	<1.1	PASSED
19-3985	Consumers' Tap	Pogo ACWD Office	<1	<1.1	<1.1	PASSED
19-3986	Consumers' Tap	Victoria End Point	<1	<1.1	<1.1	PASSED
19-3987	Consumers' Tap	Polo Brgy. Hall	<1	<1.1	<1.1	PASSED
19-3988	Consumers' Tap	Cabatuan near School	1	<1.1	<1.1	PASSED
19-3989	Consumers' Tap	Bisocol Elementary School	<1	<1.1	<1.1	PASSED
19-3990	Consumers' Tap	Inerangan Siobal	<1	<1.1	<1.1	PASSED
19-3991	Consumers' Tap	Tagudin near School	<1	<1.1	<1.1	PASSED
19-3992	Consumers' Tap	Landoc near School	<1	<1.1	<1.1	PASSED
19-3993	Consumers' Tap	Baleyadaan Elementary School	<1	<1.1	<1.1	PASSED
19-3994	Consumers' Tap	Lucap Maxine	<1	<1.1	<1.1	PASSED
19-3995	Pump House	Cabatuan I, Alaminos City	<1	<1.1	<1.1	PASSED
19-3996	Pump House	Cabatuan III, Alaminos City	<1	<1.1	<1.1	PASSED
19-3997	Pump House	Sabangan Spring	<1	<1.1	<1.1	PASSED
19-3998	Pump House	Sabangan Well	1	<1.1	<1.1	PASSED
19-3999	Pump House	Linmansangan, Alaminos City	<1	<1.1	<1.1	PASSED
19-4000	Pump House	San Vicente, Alaminos City	<1	<1.1	<1.1	PASSED
19-4001	Pump House	Balangobong I, Alaminos City	<1	<1.1	<1.1	PASSED
19-4002	Pump House	Balangobong II, Alaminos City	<1	<1.1	<1.1	PASSED
19-4003	Pump House	Quibuar I Alos	<1	<1.1	<1.1	PASSED
19-4004	Pump House	Quibuar II Alos	<1	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNSDW)

Total Coliforms = <1.1 MPN/100 ml

Thermotolerant coliform/E. coli = <1.1 MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: **Allen Valencia (ACWD)**

Examination Date: **October 25, 2019**

  
**WILLY P. DE GUZMAN, RMT**

**Analyst**