

Republic of the Philippines
 PROVINCE OF PANGASINAN
 Provincial Water Bacteriological Laboratory

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
20-1366	Consumers' Tap	Sta Maria Centro	< 1	<1.1	<1.1	PASSED
20-1367	Consumers' Tap	Pogo ACWD Office	< 1	<1.1	<1.1	PASSED
20-1368	Consumers' Tap	Victoria End Point	< 1	<1.1	<1.1	PASSED
20-1369	Consumers' Tap	Polo Brgy. Hall	< 1	<1.1	<1.1	PASSED
20-1370	Consumers' Tap	Cabatuan near School	2	<1.1	<1.1	PASSED
20-1371	Consumers' Tap	Bisocol Elementary School	< 1	<1.1	<1.1	PASSED
20-1372	Consumers' Tap	Inerangan Siobal	< 1	<1.1	<1.1	PASSED
20-1373	Consumers' Tap	Tagudin near School	< 1	<1.1	<1.1	PASSED
20-1374	Consumers' Tap	Landoc near School	20	<1.1	<1.1	PASSED
20-1375	Consumers' Tap	Baleyadaan Elementary School	1	<1.1	<1.1	PASSED
20-1376	Consumers' Tap	Lucap Maxine	1	<1.1	<1.1	PASSED
20-1377	Consumers' Tap	Palamis near School	1	<1.1	<1.1	PASSED
20-1378	Consumers' Tap	Pocal-pocal near School	< 1	<1.1	<1.1	PASSED
20-1379	Consumers' Tap	Tangcarang near School	< 1	<1.1	<1.1	PASSED
20-1380	Consumers' Tap	Poblacion near School	1	<1.1	<1.1	PASSED
20-1381	Consumers' Tap	Amangbangan near School	20	<1.1	<1.1	PASSED
20-1382	Consumers' Tap	Cayuway near School	10	<1.1	<1.1	PASSED
20-1383	Consumers' Tap	Tawin-tawin near School	< 1	<1.1	<1.1	PASSED
20-1384	Consumers' Tap	Telbang near School	< 1	<1.1	<1.1	PASSED
20-1385	Consumers' Tap	San Vicente near School	< 1	<1.1	<1.1	PASSED
20-1386	Pump House	Cabatuan I, Alaminos City	2	<1.1	<1.1	PASSED
20-1387	Pump House	Cabatuan III, Alaminos Ciity	5	<1.1	<1.1	PASSED
20-1388	Pump House	Sabangan Spring 40HP	1	<1.1	<1.1	PASSED
20-1389	Pump House	Sabangan Spring 25HP, Alaminos City	1	<1.1	<1.1	PASSED

Republic of the Philippines
 PROVINCE OF PANGASINAN
 Provincial Water Bacteriological Laboratory

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
20-1390	Pump House	Linmansangan, Alaminos City	< 1	<1.1	<1.1	PASSED
20-1391	Pump House	San Vicente, Alaminos City	< 1	< 1.1	< 1.1	PASSED
20-1392	Pump House	Balangobong I, Alaminos City	< 1	< 1.1	< 1.1	PASSED
20-1393	Pump House	Balangobong II, Alaminos City	< 1	<1.1	<1.1	PASSED
20-1394	Pump House	Quibuar I Alos	< 1	< 1.1	< 1.1	PASSED
20-1395	Pump House	Quibuar II Alos	1	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNSDW)

Total Coliforms = <1.1 MPN/100 ml
 Thermotolerant coliform/E. coli = <1.1MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: Allen Valencia (ACWD)
Examination Date: May 21, 2020


WILLY P. DE GUZMAN, RMT
 Analyst