

Republic of the Philippines  
 PROVINCE OF PANGASINAN  
 Provincial Water Bacteriological Laboratory

**BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES**

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
19-4297	Consumers' Tap	Sta Maria Centro	<1	<1.1	<1.1	PASSED
19-4298	Consumers' Tap	Pogo ACWD Office	<1	<1.1	<1.1	PASSED
19-4299	Consumers' Tap	Victoria End Point	<1	<1.1	<1.1	PASSED
19-4300	Consumers' Tap	Polo Brgy. Hall	1	<1.1	<1.1	PASSED
19-4301	Consumers' Tap	Cabatuan near School	<1	<1.1	<1.1	PASSED
19-4302	Consumers' Tap	Bisocol Elementary School	<1	<1.1	<1.1	PASSED
19-4303	Consumers' Tap	Inerangan Siobal	<1	<1.1	<1.1	PASSED
19-4304	Consumers' Tap	Tagudin near School	<1	<1.1	<1.1	PASSED
19-4305	Consumers' Tap	Landoc near School	<1	<1.1	<1.1	PASSED
19-4306	Consumers' Tap	Baleyadaan Elementary School	<1	<1.1	<1.1	PASSED
19-4307	Consumers' Tap	Lucap Maxine	<1	<1.1	<1.1	PASSED
19-4308	Pump House	Cabatuan I, Alaminos City	<1	<1.1	<1.1	PASSED
19-4309	Pump House	Cabatuan III, Alaminos City	1	<1.1	<1.1	PASSED
19-4310	Pump House	Sabangan Spring	<1	<1.1	<1.1	PASSED
19-4311	Pump House	Sabangan Well	1	<1.1	<1.1	PASSED
19-4312	Pump House	Linmansangan, Alaminos City	<1	<1.1	<1.1	PASSED
19-4313	Pump House	San Vicente, Alaminos City	<1	<1.1	<1.1	PASSED
19-4314	Pump House	Balangobong I, Alaminos City	<1	<1.1	<1.1	PASSED
19-4315	Pump House	Balangobong II, Alaminos City	1	<1.1	<1.1	PASSED
19-4316	Pump House	Quibuar I Alos	<1	<1.1	<1.1	PASSED
19-4317	Pump House	Quibuar II Alos	<1	<1.1	<1.1	PASSED

*W.P.G.*  
**WILLY P. DE GUZMAN, RMT**  
 Analyst

Heterotrophic Plate Count = <500 CFU/ml  
**Submitted by: Allen Valencia (ACWD)**  
**Examination Date: November 25, 2019**

Philippine National Standards for Drinking Water (PNSDW)  
 Total Coliforms = <1.1 MPN/100 ml  
 Thermotolerant coliform/E. coli = <1.1 MPN/100 ml