

Republic of the Philippines
 PROVINCE OF PANGASINAN
 Provincial Water Bacteriological Laboratory

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
19-4584	Consumers' Tap	Sta Maria Centro	<1	<1.1	<1.1	PASSED
19-4585	Consumers' Tap	Pogo ACWD Office	<1	<1.1	<1.1	PASSED
19-4586	Consumers' Tap	Victoria End Point	1	<1.1	<1.1	PASSED
19-4587	Consumers' Tap	Polo Brgy. Hall	<1	<1.1	<1.1	PASSED
19-4588	Consumers' Tap	Cabatuan near School	<1	<1.1	<1.1	PASSED
19-4589	Consumers' Tap	Bisocol Elementary School	<1	<1.1	<1.1	PASSED
19-4590	Consumers' Tap	Inerangan Siobal	<1	<1.1	<1.1	PASSED
19-4591	Consumers' Tap	Tagudin near School	<1	<1.1	<1.1	PASSED
19-4592	Consumers' Tap	Landoc near School	<1	<1.1	<1.1	PASSED
19-4593	Consumers' Tap	Baleyadaan Elementary School	<1	<1.1	<1.1	PASSED
19-4594	Consumers' Tap	Lucap Maxine	1	<1.1	<1.1	PASSED
19-4595	Pump House	Cabatuan I, Alaminos City	<1	<1.1	<1.1	PASSED
19-4596	Pump House	Cabatuan III, Alaminos City	<1	<1.1	<1.1	PASSED
19-4597	Pump House	Sabangan Spring	1	<1.1	<1.1	PASSED
19-4598	Pump House	Sabangan Well	<1	<1.1	<1.1	PASSED
19-4599	Pump House	Linmansangan, Alaminos City	<1	<1.1	<1.1	PASSED
19-4600	Pump House	San Vicente, Alaminos City	<1	<1.1	<1.1	PASSED
19-4601	Pump House	Balangobong I, Alaminos City	<1	<1.1	<1.1	PASSED
19-4602	Pump House	Balangobong II, Alaminos City	<1	<1.1	<1.1	PASSED
19-4603	Pump House	Quibuar I Alos	<1	<1.1	<1.1	PASSED
19-4604	Pump House	Quibuar II Alos	<1	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNSDW)

Total Coliforms = <1.1 MPN/100 ml
 Thermotolerant coliform/E. coli = <1.1 MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: **Allen Valencia (ACWD)**
 Examination Date: **December 17, 2019**


WILLYP. DE GUZMAN, RMT
 Analyst