

Republic of the Philippines
 PROVINCE OF PANGASINAN
 Provincial Water Bacteriological Laboratory

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
20-2093	Consumers' Tap	Sta Maria Centro	< 1	<1.1	<1.1	PASSED
20-2094	Consumers' Tap	Pogo ACWD Office	< 1	<1.1	<1.1	PASSED
20-2095	Consumers' Tap	Victoria End Point	< 1	<1.1	<1.1	PASSED
20-2096	Consumers' Tap	Polo Brgy. Hall	< 1	<1.1	<1.1	PASSED
20-2097	Consumers' Tap	Cabatuan near School	< 1	<1.1	<1.1	PASSED
20-2098	Consumers' Tap	Bisocol Elementary School	< 1	<1.1	<1.1	PASSED
20-2099	Consumers' Tap	Inerangan Siobal	< 1	<1.1	<1.1	PASSED
20-2100	Consumers' Tap	Tagudin near School	< 1	<1.1	<1.1	PASSED
20-2101	Consumers' Tap	Landoc near School	< 1	<1.1	<1.1	PASSED
20-2102	Consumers' Tap	Baleyadaan Elementary School	< 1	<1.1	<1.1	PASSED
20-2103	Consumers' Tap	Lucap Maxine	< 1	<1.1	<1.1	PASSED
20-2104	Consumers' Tap	Palamis near School	< 1	<1.1	<1.1	PASSED
20-2105	Consumers' Tap	Pocal-pocal near School	< 1	<1.1	<1.1	PASSED
20-2106	Consumers' Tap	Tangcarang near School	< 1	<1.1	<1.1	PASSED
20-2107	Consumers' Tap	Poblacion near School	< 1	<1.1	<1.1	PASSED
20-2108	Consumers' Tap	Amangbangan near School	< 1	<1.1	<1.1	PASSED
20-2109	Consumers' Tap	Cayucay near School	< 1	<1.1	<1.1	PASSED
20-2110	Consumers' Tap	Tawin-tawin near School	< 1	<1.1	<1.1	PASSED
20-2111	Consumers' Tap	Telbang near School	< 1	<1.1	<1.1	PASSED
20-2112	Consumers' Tap	San Vicente near School	1	<1.1	<1.1	PASSED
20-2113	Pump House	Cabatuan I, Alaminos City	< 1	<1.1	<1.1	PASSED
20-2114	Pump House	Cabatuan III, Alaminos City	< 1	<1.1	<1.1	PASSED
20-2115	Pump House	Sabangan Spring 40HP	2	<1.1	<1.1	PASSED
20-2116	Pump House	Sabangan Spring 25HP, Alaminos City	< 1	<1.1	<1.1	PASSED

Republic of the Philippines
 PROVINCE OF PANGASINAN
 Provincial Water Bacteriological Laboratory

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
20-2117	Pump House	Linmansangan, Alaminos City	< 1	<1.1	<1.1	PASSED
20-2118	Pump House	San Vicente, Alaminos City	< 1	< 1.1	< 1.1	PASSED
20-2119	Pump House	Balangobong I, Alaminos City	< 1	< 1.1	< 1.1	PASSED
20-2120	Pump House	Balangobong II, Alaminos City	< 1	<1.1	<1.1	PASSED
20-2121	Pump House	Quibuar I Alos	< 1	< 1.1	< 1.1	PASSED
20-2122	Pump House	Quibuar II Alos	< 1	<1.1	<1.1	PASSED

Philippine National Standards for Drinking Water (PNSDW)


Total Coliforms = <1.1 MPN/100 ml

Thermotolerant coliform/E. coli = <1.1MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: Allen Valencia (ACWD)

Examination Date: July 22, 2020


WILLY P. DE GUZMAN, RMT
 Analyst