

Republic of the Philippines  
 PROVINCE OF PANGASINAN  
 Provincial Water Bacteriological Laboratory

**BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES**

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
20-2919	Consumers' Tap	Sta Maria Centro	25	<1.1	<1.1	PASSED
20-2920	Consumers' Tap	Pogo ACWD Office	< 1	<1.1	<1.1	PASSED
20-2921	Consumers' Tap	Victoria End Point	2	<1.1	<1.1	PASSED
20-2922	Consumers' Tap	Polo Brgy. Hall	< 1	<1.1	<1.1	PASSED
20-2923	Consumers' Tap	Cabatuan near School	< 1	<1.1	<1.1	PASSED
20-2924	Consumers' Tap	Bisocol Elementary School	1	<1.1	<1.1	PASSED
20-2925	Consumers' Tap	Inerangan Siobal	15	<1.1	<1.1	PASSED
20-2926	Consumers' Tap	Tagudin near School	< 1	<1.1	<1.1	PASSED
20-2927	Consumers' Tap	Landoc near School	< 1	<1.1	<1.1	PASSED
20-2928	Consumers' Tap	Baleyadaan Elementary School	< 1	<1.1	<1.1	PASSED
20-2929	Consumers' Tap	Lucap Maxine	< 1	<1.1	<1.1	PASSED
20-2930	Consumers' Tap	Palamis near School	2	<1.1	<1.1	PASSED
20-2931	Consumers' Tap	Pocal-pocal near School	< 1	<1.1	<1.1	PASSED
20-2932	Consumers' Tap	Tangcarang near School	< 1	<1.1	<1.1	PASSED
20-2933	Consumers' Tap	Poblacion near School	3	<1.1	<1.1	PASSED
20-2934	Consumers' Tap	Amangbangan near School	< 1	<1.1	<1.1	PASSED
20-2935	Consumers' Tap	Cayucay near School	5	<1.1	<1.1	PASSED
20-2936	Consumers' Tap	Tawin-tawin near School	< 1	<1.1	<1.1	PASSED
20-2937	Consumers' Tap	Telbang near School	< 1	<1.1	<1.1	PASSED
20-2938	Consumers' Tap	San Vicente near School	< 1	<1.1	<1.1	PASSED
20-2939	Pump House	Cabatuan I, Alaminos City	< 1	<1.1	<1.1	PASSED
20-2940	Pump House	Cabatuan III, Alaminos Ciity	1	<1.1	<1.1	PASSED
20-2941	Pump House	Sabangan Spring 40HP	< 1	<1.1	<1.1	PASSED
20-2942	Pump House	Sabangan Spring 25HP, Alaminos City	< 1	<1.1	<1.1	PASSED

Republic of the Philippines  
 PROVINCE OF PANGASINAN  
 Provincial Water Bacteriological Laboratory

**BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES**

Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
20-2943	Pump House	Linmansangan, Alaminos City	171	<1.1	<1.1	PASSED
<b>20-2944</b>	<b>Pump House</b>	<b>San Vicente, Alaminos City</b>	<b>&gt;5,700</b>	<b>&lt; 1.1</b>	<b>&lt; 1.1</b>	<b>FAILED</b>
20-2945	Pump House	Balangobong I, Alaminos City	2	< 1.1	< 1.1	PASSED
20-2946	Pump House	Balangobong II, Alaminos City	225	<1.1	<1.1	PASSED
20-2947	Pump House	Quibuar I Alos	< 1	< 1.1	< 1.1	PASSED
20-2948	Pump House	Quibuar II Alos	< 1	< 1.1	< 1.1	PASSED

*Philippine National Standards for Drinking Water (PNSDW)*

Total Coliforms = <1.1 MPN/100 ml  
 Thermotolerant coliform/E. coli = <1.1MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

**Submitted by: Allen Valencia (ACWD)**  
**Examination Date: September 24, 2020**

  
**WILLY P. DEGUZMAN, RMT**  
 Analyst