

PROVINCE OF PANGASINAN
Provincial Water Bacteriological Laboratory

BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES


Lab. No.	Name of Establishment	Address	Results of Analysis			REMARKS
			HPC	Total Coliforms	Thermotolerant coliforms/ E. coli	
22-509	Pump House	Cabatuan I PH, Alaminos City	< 1	<1.1	<1.1	PASSED
22-510	Pump House	Cabatuan III PH, Alaminos City	2	<1.1	<1.1	PASSED
22-511	Pump House	Sabangan PH 25HP Well	1	<1.1	<1.1	PASSED
22-512	Pump House	Sabangan PH 40HP Spring	< 1	<1.1	<1.1	PASSED
22-513	Pump House	Linmansangan PH, Alaminos City	< 1	<1.1	<1.1	PASSED
22-514	Pump House	San Vicente I PH, Alaminos City	< 1	< 1.1	< 1.1	PASSED
22-515	Pump House	San Vicente II PH, Alaminos City	5	< 1.1	< 1.1	PASSED
22-516	Pump House	Balangobong I PH, Alaminos City	2	< 1.1	< 1.1	PASSED
22-517	Pump House	Balangobong II PH, Alaminos City	< 1	<1.1	<1.1	PASSED
22-518	Pump House	Quibuar I Alos PH, Alaminos City	1	< 1.1	< 1.1	PASSED
22-519	Pump House	Quibuar II Alos PH, Alaminos City	< 1	<1.1	<1.1	PASSED

2017 Philippine National Standards for Drinking Water (PNSDW)

Total Coliforms = <1.1 MPN/100 ml
 Thermotolerant coliform/E. coli = <1.1MPN/100 ml

Heterotrophic Plate Count = <500 CFU/ml

Submitted by: **Allen Valencia (ACWD)**
 Examination Date: February 18, 2022


WILLY P. DE GUZMAN, RMT
 Analyst